

From: [Brian Moore](#)
To: [Zehner, Warren](#)
Cc: [Bob Piniewski](#); [Abshire, David](#)
Subject: Malone- Injection ER Operation Request
Date: Tuesday, July 21, 2015 3:07:22 PM

Dear Warren,

We hope to move forward with the Mechanical Integrity Test (MIT) and follow up with an Injection Falloff Test on the second well (WDW-73) beginning tomorrow or Thursday this week pending one last transfer pump issue we encountered today. These test will require approximately 500,000 gallons of water. We currently only have approximately 900,000 gallons remaining on-site located in both of the concrete API basins. If we continue to inject 24/7 through WDW-138 we would need to cease injection this Thursday COB down WDW-138 to have enough volume to conduct the 2 tests on WDW-73. I have discussed the issue with David and he is OK with the cease injection to run the WDW-73 tests but requested that I discuss with you to confirm. When convenient, can you please advise or give me a call to discuss our options? Thanks for your time on this issue.

Kindest Regards,

Brian Moore
Construction Manager
Malone Superfund RD/RA
Project Navigator, Ltd.
10497 Town & Country Way, Suite 830
Houston, TX 77024
Direct: 713.468.5961
Cell: 713.534.4546
Fax: 713.468.4515



9716136